

LCSD District Wide Water Testing for Lead

All sinks and drinking fountains in LCSD schools have been tested and all results have been received at this time.

All fixtures that returned action level results have been turned off and removed, most of which have been replaced and retested at this time.

There are delays in special order faucets in addition to an average 10 business day wait for water test results. We appreciate your patience during this time.

LCSD encourages the public to visit <https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water> for lead information

School	Fixtures Tested	Action Level Results	Locations	Notes	Test Sent	Qty	To	EST Results
Yaquina View	52	24	Multiple	City of Newport replaced water meter with lead free meter on 8/2. Water sample taken from meter 8/13, results pending. Fixtures being replaced in the building 8/15-8/17. Will retest 8/18. Estimated results 8/26. 12 water stations have been placed for drinking water.	13-Aug	1	ALG	25-Aug
ECC	17	1	Bathroom Sink	Pending retest results	9-Aug	1	ALG	22-Aug
Sam Case	59	3	Classroom sinks: 32,33,38	Rm 32&38 under action levels. Rm 33 pending retest results.	9-Aug	1	ALG	22-Aug
Newport Middle	118	4	3127, 3127, 4023, kitchen	All under action levels				
Newport High West	61	6	W18,W20,W32,W35	Four under action levels. Two pending retest results.	10-Aug	2	ALG	22-Aug
Newport High East	140	17	10 science lab sinks Sinks: 2 bathroom, 2 kitchen, 1 concessions 2 classroom sinks (e17,e19)	Science labs will be posted as non potable water. All others are pending retest results.	15-Aug	7	ALG	29-Aug
Crestview	91	4	5, 6a, 27, 31	Pending retest results	5-Aug	4	UMP	17-Aug
Waldport High	86	3	234,241,241	Pending retest results for two, fixture for shop has been ordered but has not arrived yet. Will be installed and retested asap.	5-Aug	2	UMP	17-Aug
Toledo Elementary	81	1	106 classroom sink	Pending retest results	8-Aug	1	UMP	22-Aug
Toledo High	99	16	7 science lab sinks, Sinks: 3 bathroom, 2 office 4 classroom sinks	Science labs will be posted as non potable water. All others are pending retest results.	15-Aug	9	ALG	29-Aug
Oceanlake	78	3	1 bathroom sink 2 classroom sinks	Pending retest results. Also changed and retested one kitchen faucet that returned just below action level.	10-Aug	4	ALG	22-Aug
Taft Elementary	90	0		All under action levels				
Taft High	144	1	156 sink	Pending retest results	12-Aug	1	ALG	24-Aug