

# LCSD District Wide Water Testing for Lead

All sinks and drinking fountains in LCSD schools have been tested and any necessary remedies have been completed at this time. Some locker rooms, science labs and wash sinks have been posted as non-potable water, all other fixtures are under EPA action level.

LCSD encourages the public to visit <https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water> for lead information

School	Initial Fixtures Tested	Action Level Results	Locations	Notes	Total Tests as of 9/1/16
Yaquina View	52	24	Multiple	City meter, main water line, fixtures, and some supply lines replaced. Kitchen dish wash sink has been posted as non-potable water, remainder of building is under action level	164
ECC	17	1	Bathroom Sink	All under action level	18
Sam Case	59	3	Classroom sinks: 32,33,38	All under action level	61
Newport Middle	118	4	3127, 3127, 4023, kitchen	Locker room showers have been posted as non-potable water, remainder of building is under action level	139
Newport High West	61	6	W18,W20,W32,W35	Removed W20 bubbler, provided drinking station. All under action level	79
Newport High East	140	17	10 science lab sinks Sinks: 2 bathroom, 2 kitchen, 1 concessions 2 classroom sinks (e17,e19)	Science labs, kitchen dish sink and two restroom sinks have been posted as non-potable water, remainder of building is under action level	172
Crestview	91	4	5, 6a, 27, 31	All under action level	101
Waldport High	86	3	234,241,241	Locker room showers have been posted as non-potable water, remainder of building is under action level	113
Toledo Elementary	81	1	106 classroom sink	All under action level	88
Toledo High	99	16	7 science lab sinks, Sinks: 3 bathroom, 2 office 4 classroom sinks	Science labs and locker room showers have been posted as non-potable water, remainder of building is under action level	140
Oceanlake	78	3	1 bathroom sink 2 classroom sinks	All under action level	88
Taft Elementary	90	0		All under action level	96
Taft High	144	1	156 sink	All under action level	177

1116

83

1436